

EQUIVALENT SOUNDABSORPTION AREA PER OBJECT conform ISO 354:2003




principal: BuzziSpace

#5; BuzziHug



— 1/3 oct.
* 1/1 oct.



	1,00	1,79	3,36	4,45	5,74	6,32
1/3 oct.	1,42	2,44	3,98	4,69	5,95	6,24
	1,69	2,94	4,13	5,18	6,44	6,22
1/1 oct.	1,37	2,39	3,82	4,77	6,04	6,26

Absorb, versie 5.9 mode 9, PM: RA, file: a3898 E#:398-431 F#:580-615 A#:616 T₁ = 16,4 °C T₂ = 17,0 °C p₁ = 102,0 kPa p₂ = 102,1 kPa h₁ = 51,1 % h₂ = 49,9 %
 volume reverberation room: 214 m³
 number of elements: 2
 measured at: Peutz Laboratory for Acoustics
 signal: broad-band noise
 bandwidth: 1/3 octave

publication is permitted for the entire page only

Mook, measured at 08-04-2021